



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

<p>Violation #5. Maintenance &amp; Repair Mop sink with no hot water with pressure on the 2nd and 3rd floor. Use the 1st floor mop sink until 2nd and 3rd mop sink has been repaired. This is a Repeat violation.</p> <p>CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components &amp; finishes shall be kept clean &amp; in good repair.</p>
<p>Violation #6. Lighting Standards Replace some burned-out light bulbs in rooms 329, 226 and 114.Observed CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.</p>
<p>Violation #13. Handwashing Facilities Repair one faucet in restrooms # 101( third faucet ). It observed water line is closed because the leak from the pipe under the sink.</p> <p>CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.</p>

Inspection Conducted By: Beatriz Rodriguez (60752)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name:  
Date: 2/24/2021

Inspector Signature:

Handwritten signature of Beatriz Rodriguez.

Client Signature:

Email to: Guillermo Moron 2-24-21